

**HYDERABAD DISASTER RESPONSE AND ASSET PROTECTION AGENCY
(HYDRAA)**

From
The Commissioner,
Hyderabad Disaster Response
And Asset Protection Agency
(HYDRAA)



To
The Management,
"The Hyderabad Public School",
H.No.3-8-152 A to L, Sy.No.15/1 & 15/2,
Ramanthapur, Uppal, Hyderabad.


RC.No.920/COMM./HYDRAA/2025, Dated: 21.11.2025.

Sub : - HYDRAA - Disaster Management Wing - Existing Non High Rise Educational Building of "The Hyderabad Public School" consisting of Ground+ 1 Upper Floor, situated at H.No.3-8-152 A to L, Sy.No.15/1 & 15/2, Ramanthapur, Uppal, Hyderabad - **Renewal of Fire No Objection Certificate - Issued - Regarding.**

- Ref : -
- 1) Proceeding Rc. No. 5041/B2/97, Dated: 12.03.2010 of the Director General of the State Disaster Response and Fire Services, A.P., Hyd.
 - 2) Proceedings No. DM/0011/2018/D (VK) EVDM/2018, dt. 29.06.2018 of the Commissioner, GHMC.
 - 3) G.O.MS.No. 99 of MA&UD (GHMC. I) Dept, Dated 19.07.2024.
 - 4) Renewal of Fire No Objection Certificate vide Rc.No.3309/COMM./HYDRAA/2024, Dated: 29.11.2024, issued by the Commissioner, HYDRAA.
 - 5) Application of Dr. S. Narasimha Reddy, received through Inward No.920, Dated: 12.11.2025.
 - 6) Inspection Report Dated: 21.11.2025.

1. Vide reference 4th cited, the Renewal of Fire No Objection Certificate was issued to Existing Non High Rise Educational Building of "The Hyderabad Public School" consisting of Ground+ 1 Upper Floor, situated at H.No.3-8-152 A to L, Sy.No.15/1 & 15/2, Ramanthapur, Uppal, Hyderabad.
2. Vide reference 5th cited, the owner has applied for the Renewal of Fire No Objection Certificate.
3. Vide reference 6th cited, the team has inspected the above building and submitted the following report.
4. Particulars of the Building:

a)	Name & Address of the building	"The Hyderabad Public School", H.No.3-8-152 A to L, Sy.No.15/1 & 15/2, Ramanthapur, Uppal, Hyderabad
b)	Plot Area/Height	149795.06 Sq. Meters/ 08.70 Meters
c)	No of floors	Ground + 1 Upper Floor
d)	Name of the Owner with mobile no.	Dr. S.Narsimha Reddy, 9849503003
e)	Map Location	17.399719 78.536644



..2..

5. Floor wise details:

Sl. No.	Floor	Area in Sq. Meters	Type of Occupancy	Maximum Occupant Load as per Floor Area
1	Ground Floor	2654.36	Educational (B-1)	664
2	First Floor	2186.42	Educational (B-1)	547
Total		4840.78	-	-

6. Open spaces all around the building:

Sl. No.	Directions	Required as per Hon'ble Supreme Court Orders/Renewal Fire NOC	Provided	Deficit
1	FRONT (East)	6.00 Meters	6.00 Meters	Nil
2	SIDE I (North)	6.00 Meters	6.00 Meters	Nil
3	SIDE II (South)	6.00 Meters	6.00 Meters	Nil
4	REAR(West)	6.00 Meters	6.00 Meters	Nil

7. Means of escape:

7. Means of escape:						
Sl. No.	Staircases	Required as per NBC-2005/Occupant Load		Provided		Deficit
		Nos.	Width	Nos.	Width	
1	Internal/ External	04	5.47 Meters	01	1.40 Meters	Nil
				01	1.15 Meters	
				01	1.50 Meters	
				01	1.30 Meters	Nil
				01	1.10 Meters	
Total				05	6.45 Meters	-

8. The Minimum Fire Safety Installations required & provided by the builder as per the Table 7 of Part-4 of N.B.C of India 2016.

Sl. No	Fire Safety Installations	Required	Provided	Deficit
1	Fire Extinguishers	49 Nos.	49 Nos.	Nil
2	First Aid Hose Reel	06 Nos.	08 Nos.	Nil
3	Down Comer	NR	04 Nos.	Nil
4	Manually Operated Electronic Fire Alarm Systems	NR	20 No.	Nil
5	Terrace Tank over Respective Tower Terrace	10,000 Litres	10,000 Litres	Nil
6	Pump at the Terrace Tank level with Minimum Pressure of 3.5 Kg/Cm ²	1 No. Booster Pump of 450 LPM	1 No. Booster Pump of 450 LPM	Nil

Terms & Conditions: -

1. The Renewal of Fire NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use / Occupancy or Building Regularization. The Owner / Occupier shall comply with the Building Rules /Govt. Orders as applicable.

::3::

2. Fixed and first-aid Fire Fighting equipment, alarm etc., shall be tested and maintained regularly as per applicable standards and Fire-Drills conducted quarterly for first two years and half yearly after two Years. Also expired equipment should be replaced immediately.
3. Emergency power generator etc. and associated equipment should be tested periodically, verified as per NBC, and IS-1646.
4. Adequate ventilation should be provided in all floors of the building.
5. Every room with a capacity of 45 students shall be provided with minimum two doorways.
6. Evacuation plan at showing exit routes and recommended action plan be displayed at conspicuous locations and shall be exhibited all times, all escape /exit routes shall not be blocked or encroached.
7. Fresh NOC would be required for any change in occupancy or additions/ alterations in the building structure as per NBC of India and building bye/laws.
8. The Management has to maintain Fire Safety Measures at all times in good working Condition as seen during the inspection.
9. This order will be without any prejudice to take action against the Un-authorized construction if any made.
10. Any Loss of life or property due to Non - functioning of Fire Safety Measures and other installations shall be the responsibility of the management/ owner.
11. All the Occupants must know the correct method of operation of the First Aid Fire Fighting System installed.
12. All Security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
13. This Renewal of Fire No Objection Certificate is **valid for one (1) year** i.e., up to **29.11.2026** and it is the responsibility of the owner/occupier to apply for the Renewal, two months before its expiry.

In view of the above, the **Renewal of Fire No Objection Certificate** is issued to the Existing Non High Rise Educational Building of "The Hyderabad Public School" consisting of Ground+ 1 Upper Floor, situated at H.No.3-8-152 A to L, Sy.No.15/1 & 15/2, Ramanthapur, Uppal, Hyderabad.


Commissioner
Hyderabad Disaster Response
and Asset Protection Agency
(HYDRAA)

Commissioner
HYDRAA,